

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2/24-25

Dated: 21-2-24

It is certified that an inspection team headed by A.M. Kumar V., Health Inspector

(Name of Officers with designation) from Health Service Dept. PHC Konnakkad PHED

inspected the St. Savio English Medium School, Vallikadavu

(Name & Address of the school) on 15-2-24 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. KNA/LAB/102/139/15/12/20 dated 13-02-2024

of KNA Lab, Kasaragode (PHED Lab) certified that the

St. Savio English Medium School, Vallikadavu (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 12-08-2024

Signature with Seal: 

Name : A.M. Kumar V.

Designation : Health Inspector

Name & Address of the Office / Department : PHC Konnakkad

To St. Savio English Medium School

Vallikadavu
(Name & Address of the Institution)


HEALTH INSPECTOR
PHC KONNAKKAD
KONNAKKAD P.O.
KASARAGOD DT.


Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

For ST. SAVIO ENGLISH MEDIUM SCHOOL
P.O. Vallikadavu, Kasaragod Dt.

Sandhya
Principal

Nisha
Principal






KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB KASARAGOD, VIDYANAGAR
WATER ANALYSIS REPORT


Tele phone No : 04994 255791
email : qclabkasaragod@gmail.com

Report No - KWA/QA/R/02/139/1/12/207		13/02/2024			
Customer Name and Address ST SAVIO ENGLISH MEDIUM SCHOOL C/O PRINCIPAL, VALLIKKADAVU P O VELLARIKUNDU VIA KASARAGOD 671534 Phone : 8289968040 HI PHC Konnakkad		1. Date of receipt	:12/02/2024		
		2. Sample Provided by	Customer (QUA_108512)		
		3. Sample Code	23/24 (72)		
		4. Source of Sample	Open Well		
		5. Sample quantity	: 100ml		
		6. Test performing dates	From:12/02/2024 To: 13/02/2024		
Sl No	Characteristics	3. Sample Code	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Total Coliforms	CFU /100 ml	IS 15185:2016; ISO 9308 - 1: 2014	Nil	Nil
2	<i>E.coli.</i>	CFU /100 ml	IS 15185:2016; ISO 9308 - 1: 2014	Nil	Nil

Remarks:

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the laboratory.


Analysed By
Bacteriologist


As Authorised Engineer
Quality Control District Lab
Kerala Water Authority
Assistant Engineer

* End Of Report*

KWA/QC/DL/KSD/R/17

Issue No: 02

Issue Date : 06.05.2022


Rev No: 001


Rev Date:

06.05.2022

Page 2 of 2

For ST. SAVIO ENGLISH MEDIUM SCHOOL
P. O. VALLIKKADAVU - 671534


Manager


Principal